

DECLARATION OF CONFORMITY

BELIMO Automation
Brunnenbachstrasse 1
CH-8340 Hinwil / Switzerland

We declare that the product types

R20.., R30.., R60..R.., R70..R..
DN15 –DN50

To which this declaration relates, are in conformity with the following directive(s), standard(s) or normative document(s):

Pipe connection: R20../R30.. – Rp (ISO 7/1)
R60..R../R70..R.. – Compatible with PN6 (EN1092/1)

Products: according to Directive PED 97-23-EC Art. 3 §3 and Art. 3 §1.3(a)

Type	Body Mark *	PN / Ps	Trim Material	DN ≤ 32	DN ≥ 40
R20..S.. / R30..S..	4140 kPa	1600 kPa	Stainless Steel	Art. 3 §3	---
R20..B.. / R30..B..	4140 kPa	1600 kPa	Brass	Art. 3 §3	---
R20..S.. / R30..S..	2760 kPa	1600 kPa	Stainless Steel	Art. 3 §3	Art. 3 §1.3(a) †
R20..B.. / R30..B..	2760 kPa	1600 kPa	Brass	Art. 3 §3	Art. 3 §1.3(a) †
R60..R.. / R70..R..	4140 kPa	600 kPa	Brass	Art. 3 §3	---
R60..R.. / R70..R..	2760 kPa	600 kPa	Brass	Art. 3 §3	Art. 3 §1.3(a) †

Notes -

* - Body pressure marking reflects the body rating at 20°C. It does not relate to the assembly when combined with flanges (R60..R.. / R70..).

† - CE marking is present, even though it is marketed for use at lower specifications.

Products according to PED – Article 3 §3 are NOT CE marked

Hinwil, March 06, 2012



Dieter Müller
Head of Development